



In accordance with Construction Products Regulation EU No 305/2011

Declaration of Performance No: AROH

1 Product Type

Wireless multi-criteria detector for use in fire detection and alarm systems

2 Models

Axis-ROH

3 Intended Use:

Fire Safety – Fire detection and fire alarm systems

4 Manufactured by:

Advanced Electronics Ltd,
The Bridges, Balliol Business Park,
Newcastle-Upon-Tyne.
NE12 8EW
United Kingdom

In the manufacturing plant:

Argus Security S.r.l
Via Josip 2/7
S Dorligo della Valle
24018
Trieste
Italy

5 Authorised Representative

Halma Europe DS BV
J. Keplerweg 14
2408AC
Alphen aan Den Rijn
Netherlands

We, Advanced Electronics Ltd., have appointed Halma Europe DS BV by official mandate as our authorised representative within, and importer of products into, the European Union.

6 System of Assessment and verification of constancy of performance

System 1

7 Harmonised Standards

BRE Global Ireland 2831 performed initial type testing and initial inspection of the manufacturing plant and factory production control, and performs continuous surveillance of the factory production control under system 1 and has issued a certificate of conformity 2831-CPR-F2065 to:

EN 54-5:2000 +A1:2002

EN 54-7:2000 +A1:2002 +A2:2006

EN 54-25:2008

8 European Technical Assessment

Not applicable

9 Declared Performance

Essential Characteristic	Performance	Harmonised technical specification
Nominal activation conditions/sensitivity, response delay (response time and Performance under fire conditions	Pass	EN 54-5:2000 +A1:2002 Clauses 4.2, 4.3, 5.2 to 5.6, 5.8, 6.2 (Suffix R)
Operational reliability	Pass	EN 54-5:2000 +A1:2002 Clauses 4.4 to 4.11
Tolerance to supply voltage	Pass	EN 54-5:2000 +A1:2002 Clause 5.7
Durability of operational reliability and response delay, temperature resistance	Pass	EN 54-5:2000 +A1:2002 Clauses 5.9, 5.10
Durability of operational reliability, vibration resistance	Pass	EN 54-5:2000 +A1:2002 Clauses 5.14 to 5.17
Durability of operational reliability, humidity resistance	Pass	EN 54-5:2000 +A1:2002 Clauses 5.11, 5.12
Durability of operational reliability, corrosion resistance	Pass	EN 54-5:2000 +A1:2002 Clause 5.13
Normal activation conditions/sensitivity, response delay (response time) and performance under fire conditions	Pass	EN 54-7:2000 +A1:2001 +A2:2006 Clauses 4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18
Operational reliability	Pass	EN 54-7:2000 +A1:2002 +A2:2006 Clauses 4.2 to 4.7, 4.9 to 4.11
Tolerance to supply voltage	Pass	EN 54-7:2000 +A1:2002 +A2:2006 Clause 5.5
Durability of operational reliability and response delay, temperature resistance	Pass	EN 54-7:2000 +A1:2002 +A2:2006 Clauses 5.8, 5.9
Durability of operational reliability, vibration resistance	Pass	EN 54-7:2000 +A1:2002 +A2:2006 Clauses 5.13 to 5.16
Durability of operational reliability, humidity resistance	Pass	EN 54-7:2000 +A1:2002 +A2:2006 Clauses 5.10, 5.11
Durability of operational reliability, corrosion resistance	Pass	EN 54-7:2000 +A1:2002 +A2:2006 Clause 5.12
Durability of operational reliability, electrical stability	Pass	EN 54-7:2000 +A1:2002 +A2:2006 Clause 5.17
Performance parameters under fire conditions	Pass	EN 54-25:2008 Clauses 4.1, 4.2.2, 5.2, 8.3.7
Response delay (response time to fire)	Pass	EN 54-25:2008 Clauses 8.2.3, 8.2.6
Operational reliability	Pass	EN 54-25:2008 Clauses 4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7 to 8.2.9, 8.3.1 to 8.3.6
Durability of operational reliability, temperature resistance	Pass	EN 54-25:2008 Clauses 8.3.9 to 8.3.11
Durability of operational reliability, vibration resistance	Pass	EN 54-25:2008 Clauses 8.3.16, 8.3.17, 8.3.19
Durability of operational reliability, humidity resistance	Pass	EN 54-25:2008 Clauses 8.3.13, 8.3.14
Durability of operational reliability, corrosion resistance	Pass	EN 54-25:2008 Clause 8.3.15
Durability of operational reliability, electrical stability	Pass	EN 54-25:2008 Clause 8.3.20

10 Authority

The performance of the product(s) identified in points 1 and 2 is (are) in conformity with the declared performance detailed in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:
Mr Jayson Shepherd – Product Compliance Officer

A handwritten signature in black ink, appearing to read 'Jayson Shepherd', written in a cursive style.

01 January 2021