

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F2769

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

20-AS3500-ADV Conventional Category P Heat Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Advanced Electronics Limited
The Bridges
Balliol Business Park
Newcastle Upon Tyne
NE12 8EW
United Kingdom

Argus Security Srl
Via del Canneto 14
Valle delle Noghère
34015 Muggia
Trieste
Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2028 – Heat detectors – Point heat detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 29 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P. Halligan, Certification Engineer

Date of First Issue: 29 October 2019

Date of Issue: 6 September 2022

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2769**20-AS3500-ADV Conventional Category P Heat Detector****Bases:**

20-AB100-ADV – Universal adaptor base
20-ABS100-ADV – Deep adaptor base
20-ABR100-ADV – Universal adaptor base with resistor
20-ABSR100-ADV – Deep adaptor base with resistor
20-ABDR100-ADV – Universal adaptor base with resistor and Schottky diode
20-ABSRD100-ADV – Deep adaptor base with resistor and Schottky diode

Heat Classifications:

Category A1R
Category B



P. Halligan, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 29 October 2019
Date of issue: 6 September 2022
Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie