

Certificate of Product Approval

Certificate Number: 544b Issue: 02

LPCB CERTIFICATION CON CERTIFI

Advanced Electronics Limited

34 Moorland Way Nelson Park Cramlington, Northumberland NE23 1WE United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Control and Indicating Equipment

QuickZone QuickZone XL QuickZone XL 16-32

Standards

EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Eman Mattie-Suleiman

Verifier

12 August 2016 Date of Issue 20 December 2013

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Certified Product	Description	LPCB Ref.No.
QuickZone	2 and 4 Zone Conventional Control and Indicating Equipment	544b/01
	QuickZone 2 (QZ-2)	
	Incorporating as modular units:	
	incorporating as modular units.	
	TPC A01 QuickZone 2 (QZ-2) main PCB applicable on 2 zone CIE only	
	TPC A02 QuickZone LED display PCB	
	PSM1.5 – 24 Power supply 1.5A rated	
	Certified with the following options with requirements from EN 54 Part 2:	
	7.8 Output to fire alarm devices	
	7.12.1 Dependence on more than one alarm signal (Type A)	
	10 Test Condition	
	QuickZone 4 (QZ-4)	
	Incorporating as modular units:	
	TPC A01 QuickZone 4 (QZ-4) main PCB applicable on 4 zone CIE only	
	TPC A02 QuickZone LED display PCB	
	PSM1.5 – 24 Power supply 1.5A rated	
	Certified with the following options with requirements from EN 54 Part 2:	
	7.8 Output to fire alarm devices	
	7.12.1 Dependence on more than one alarm signal (Type A)	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Eman Mattie-Suleiman

12 August 2016

20 December 2013

Verifier

Date of Issue

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Certified Product	Description	LPCB Ref.No.
	10 Test Condition	
	Note:	
	 This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13. 	
QuickZone XL	4, 8 and 12 Zone Conventional Control and Indicating Equipment	544b/02
	QuickZone XL 4 Conventional Control Panel (QZXL-4)	
	Incorporating as modular units:	
	TPCA01-X4 QuickZone XL 4 Zone Main PCB	
	TPCA03 QuickZone XL Display Board	
	PSM3.0-24 Power Supply	
	QuickZone XL 8 Conventional Control Panel (QZXL-8)	
	Incorporating as modular units:	
	TPCA01-X4 QuickZone XL 4 Zone Main PCB	
	TPCA03 QuickZone XL Display Board	
	QZXL-ZEC QuickZone XL Standard 4 Zone Extension Board	
	PSM3.0-24 Power Supply	
	QuickZone XL 8 Conventional Control Panel (QZXL-8HS)	
	Incorporating as modular units:	
	TPCA01-X4 QuickZone XL 4 Zone Main PCB	
	TPCA03 QuickZone XL Display Board	
	QZXL-HSZEC QuickZone XL High Spech 4 Zone Extension Board	
	PSM3.0-24 Power Supply	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Eman Mattie-Suleiman

12 August 2016

20 December 2013

Date of Issue

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Certified Product	Description	LPCB Ref.No.
	QuickZone XL 12 Conventional Control Panel (QZXL-12) TPCA01-X4 QuickZone XL 4 Zone Main PCB TPCA03 QuickZone XL Display Board QZXL-ZEO QuickZone XL Standard 4 Zone Extension Board QZXL-ZEC QuickZone XL High Spec 4 Zone Extension Board PSM3.0-24 Power Supply	
	QuickZone XL 12 Zone Conventional Control Panel (QZXL-12HS) TPCA01-X4 QuickZone XL 4 Zone Main PCB TPCA03 QuickZone XL Display Board QZXL-HSZEC Two QuickZone XL Standard 4 Zone Extension Board PSM3.0-24 Power Supply	
	Certified with the following options with requirements from EN 54 Part 2: 7.8 Output to fire alarm devices 7.11 Delays to outputs 7.12.1 Dependence on more than one alarm signal (Type A) 7.12.2 Dependence on more than one alarm signal (Type B) 7.12.3 Dependence on more than one alarm signal (Type C) Test Condition	
	Note: This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

Eman Mattie-Suleiman

12 August 2016

20 December 2013

Verifier

Date of Issue

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Certified Product	Description	LPCB Ref.No.
QuickZone XL 16-32	16, 24 and 32 Zone Conventional Control and Indicating Equipment	544b/03
	QuickZone XL16 (QZXL-16) 16 Zone Conventional Control Panel	
	Incorporating as modular units:	
	TPCA10 32 Zone LED display PCB	
	TPCA11-16 16 Zone Main PCB	
	TPCA12 Power supply PCB	
	and as optional modules	
	TPCR01 Relay PCB	
	TPCR03 Isolate Switch PCB TPCA09 Sounder Card PCB	
	TPCA08 Output Card PCB	
	TPCA05 XLEN Communications Board	
	QuickZone XL24 (QZXL-24) 24 Zone Conventional Control Panel	
	Incorporating as modular units:	
	TPCA10 32 Zone LED display PCB	
	TPCA11-24 24 Zone Main PCB	
	TPCA12 Power supply PCB	
	and as optional modules	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Eman Mattie-Suleiman

12 August 2016

20 December 2013

Date of Issue

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Certified Product	Description	LPCB Ref.No.
	TPCR01 Relay PCB	
	TPCR03 Isolate Switch PCB	
	TPCA09 Sounder Card PCB	
	TPCA08 Output Card PCB	
	TPCA05 XLEN Communications Board	
	QuickZone XL32 (QZXL-32) 32 Zone Conventional Control Panel	
	Incorporating as modular units:	
	TPCA10 32 Zone LED display PCB	
	TPCA11-32 32 Zone Main PCB	
	TPCA12 Power supply PCB	
	and as optional modules	
	TPCR01 Relay PCB	
	TPCR03 Isolate Switch PCB	
	TPCA09 Sounder Card PCB	
	TPCA08 Output Card PCB	
	TPCA05 XLEN Communications Board	
	Certified with the following options with requirements from EN 54 Part 2:	
	7.8 Output to fire alarm devices	
	7.9.1 Output to fire alarm routing equipment	
	7.11 Delays to outputs	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Eman Mattie-Suleiman

12 August 2016

20 December 2013

Date of Issue

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com







Certified Product	Description	LPCB Ref.No.
	7.12.1 Dependence on more than one alarm signal (Type A)	
	7.12.2 Dependence on more than one alarm signal (Type B)	
	7.12.3 Dependence on more than one alarm signal (Type C)	
	10 Test condition	
	Note:	
	1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Eman Mattie-Suleiman

12 August 2016

20 December 2013

Date of Issue

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



